NFPA 37-2002 Installation and use of stationary combustion engines and gas turbines

NFPA 37-2002 Standard for the installation and use of stationary combustion engines and gas turbines (The following Indiana Amendments are reprinted here from the Indiana government web site for your convenience. We have not edited or reformatted these pages, nor have we reviewed the for accuracy. We assume them to be identical to the official amendments as originally printed in the Indiana Register. We make no stated or implied claim as to their accuracy.)

675 IAC 28-1-15 NFPA 37; standard for the installation and use of stationary combustion engines and gas turbines

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 10-19-2; IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 15. (a) That certain standard, being titled NFPA 37, Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines, 2002 Edition, published by National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, Massachusetts 02269-9101, be and the same is hereby adopted by reference as if fully set out in this section except as revised hereafter.

- (b) The following documents referenced in NFPA 37, are not adopted, are not enforceable, and are for information purposes only:
 - (1) NFPA 11A.
 - (2) NFPA 12A.
 - (3) NFPA 30.
 - (4) NFPA 54.
 - (5) NFPA 211.
 - (6) NFPA 750.
 - (7) API 620.
 - (8) API 650.
 - (9) ANSI/ASME B31.3.
 - (10) MSS SP-69.
 - (c) The following documents are adopted and are enforceable:
 - (1) NFPA 10 adopted in section 2 of this rule.
 - (2) NFPA 12 adopted in section 4 of this rule.
 - (3) NFPA 13 adopted in 675 IAC 13-1-8.
 - (4) NFPA 15 adopted in section 8 of this rule.
 - (5) NFPA 17 adopted in section 9 of this rule.
 - (6) NFPA 58 adopted in 675 IAC 22-2.2-14.
 - (7) NFPA 70 adopted in 675 IAC 17.
 - (8) NFPA 72 adopted in section 28 of this rule.
 - (9) NFPA 2001 adopted in section 40 of this rule.
 - (10) ANSI/ASME Boiler and Pressure Vessel Code, as adopted at 680 IAC 2-1-1 [675 IAC 30-1-1]
 - (d) Amend Section 1.4 by deleting in its entirety and substituting "See 675 IAC 12-6-11.".
 - (e) Amend Section 1.7 as follows:
 - (1) Amend the following definitions:

APPROVED means acceptance by the authority having jurisdiction by one (1) of the following methods:

- (1) Investigation or tests conducted by nationally recognized authorities; or
- (2) Investigation or tests conducted by nationally recognized technical or scientific organizations; or
- (3) Nationally accepted principles.

The investigation, tests, or principles shall establish that the method, material, equipment, design, or type of construction is safe for its intended purpose.

AUTHORITY HAVING JURISDICTION means the Division of Fire and Building Safety or officer of a local unit of government empowered by law to administer and enforce the rules of the commission.

(2) Add the following definitions:

DIVISION OF FIRE AND BUILDING SAFETY means the Division of Fire and Building Safety of the Indiana Department of Homeland Security created pursuant to IC 10-19-2.

ELECTRICAL CODE means the Indiana Electrical Code in effect in Indiana at the time of construction, remodeling, alteration, addition, or repair of the structure.

INDIANA FIRE CODE means the rules adopted at 675 IAC 22 in effect in Indiana at the time of inspection by the inspection authority or, with respect to construction required to be filed under 675 IAC 12-6, 675 IAC 22 in effect at the time of construction, remodeling, alteration, addition, or repair of the structure.

NFPA 30 means the Indiana Fire Code.

NFPA 70 means the Indiana Electrical Code (675 IAC 17).

TRAINED means one who has undergone the instructions necessary to design, install, and perform maintenance and inspections.

(f) Chapter 2 and the annexes are not adopted as part of this code and are intended for use as a guide, and the standards reference therein are not enforceable as part of this code.

(Fire Prevention and Building Safety Commission; 675 IAC 28-1-15; filed Aug 23, 2006, 4:03 p.m.: 20060906-IR-675050104FRA; readopted filed Aug 8, 2012, 8:08 a.m.: 20120905-IR-675120260RFA; readopted filed Jul 3, 2018, 2:22 p.m.: 20180801-IR-675180204RFA)